



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**

**Scott Walker, Governor**  
**Dave Ross, Secretary**

August 20, 2013

PITTSVILLE HOMES, INC.  
CHERYL RAASCH  
5094 SECOND AVE  
PO BOX C  
PITTSVILLE WI 54466

Re: Description: PREFABRICATED PLUMBING SYSTEM  
Manufacturer: PITTSVILLE HOMES, INC.  
Product Name: TWO STORY MANUFACTURED HOME  
Model Number(s): ALL  
Product File No: 20120388

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2018.

This approval is contingent upon compliance with the following stipulation(s):

1. The flowing water supply pressure at the point(s) of connection must be at least 42 psig.
2. The manufacture must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
3. This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Timothy J. Lamb  
Plumbing Plan Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
Madison WI 53703-2658  
608-266-9647 Phone  
608-267-9723 Fax  
tim.lamb@wi.gov E-mail